

# IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

## The Peck Water system Does/Did Not Meet Treatment Requirements

Our water system recently violated a drinking water standard. Although this situation does not require that you take immediate action, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

Contact Time - In order to ensure proper disinfection, water in the treatment plant must be in contact with chlorine or a similar disinfectant for a minimum amount of time. On 12/28-2024, this did not occur. Although chlorine quickly kills most bacteria, it is less effective against organisms such as viruses and parasites. For this reason, water needs to mix with chlorine for a longer time period to kill such organisms. The amount of time necessary, or the Contact Time, depends on the amount of disinfectant in the water and the temperature of the water.

### What should I do?

- 👉 **You do not need to boil your water or take other corrective actions.** However, if you have specific health concerns, consult your doctor.
- \$ People with severely compromised immune systems, infants, and some elderly may be at increased risk. These people should seek advice about drinking water from their health care providers. General guidelines on ways to lessen the risk of infection by microbes are available from EPA's Safe Drinking Water Hotline at 1 (800) 426-4791.

### What does this mean?

This situation does not require that you take immediate action. If it had been, you would have been notified immediately. Tests taken during this same time period did not indicate the presence of bacteria in the water.

*Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.*

These symptoms, however, are not caused only by organisms in drinking water, but also by other factors. If you experience any of these symptoms and they persist, you may want to seek medical advice.

### What happened? What is being done?

This event occurred during a change in procedures and was quickly found and fixed.

We sampled disinfectant levels and adjusted the amount of disinfectant added as necessary to maintain adequate levels.

Disinfectant residual levels/contact times for the previous month and since have met all requirements.

For more information, please contact City of Peck at 1 (208) 486-7791 or P.O. Box 105 Peck, ID

This notice is being sent to you by The Peck Water System.